

**REQUEST FOR INFORMATION
FOR
COUNTY OF SAN MATEO**

**LISTED BELOW ARE THE QUESTIONS (Q) SUBMITTED BY
POTENTIAL BIDDERS FOR THE**

60 INCH CULVERT REPLACEMENT PROJECT AT BEAR GULCH ROAD

**COUNTY PROJECT NO. RW927
PROJECT FILE NO. E5030**

**THE COUNTY OF SAN MATEO DEPARTMENT OF PUBLIC WORKS
HAS PROVIDED RESPONSES (R) TO THE QUESTIONS BELOW**

Q1. Will the work on this project be happening this year?

R1. Yes, the work on this project will need to start and be completed this year (2022).

Q2. Please advise as to the stream flows bidding contractors are to assume to occur during the course of the project so we may appropriately size/price the diversion system for this project.

R2. The Contractor is advised that the County does not have any historical flow data on Clear Creek and will rely on the Contractor to design the temporary creek diversion system. For bidding purposes the Contractor can assume that at 15" diameter pipe will need to be installed for the by-pass system. It is required for the bidder to visit the site to understand the existing site conditions, including the flow conditions of Clear Creek - a completed Acknowledgement of Site Visit Form is required with the bid submittal.

Q3. Who is to provide the biologist for the project and perform the corresponding environmental assessment / direction, the contractor or the owner?

R3. The County will provide biologist(s) to perform the biological monitoring work and provide direction to the Contractor during construction.

Q4. Who is to provide the arborist for any tree removal, the contractor or the owner?

R4. The County will have an arborist available to provide direction or approval for tree removal work.

Updated as of **July 1, 2022 at 9:30 A.M.**

\\dpw.sanmateocounty.ads\data\Users\design\C3D\E5030000_Bear Gulch\14 Bid Process\RFI\RFI_County Responses.docx