

## Fire Marshal's Office San Mateo County Fire CAL FIRE

Date: Dec. 17, 2003

Revised: Aug. 28, 2016

Number: *CFS-009* 

320 Paul Scannell Drive, San Mateo, California 94402 (650) 573-3846

Title: Turnout Specification Approved: Mark Mondragon

## **SCOPE:**

This document is intended to provide the information required to install a turnout on a Fire Access Road meeting the requirements of the San Mateo County Fire Marshals Office.


## **Construction Guidelines:**

Surface shall be a minimum of twenty foot wide (20') for fire access lanes, be an all-weather surface and shall be able to support a fire apparatus weighing a minimum of 75,000 lbs. An engineer's certification may be required for your project.

Turnout shall consist of a 35' long improved surface meeting this standard with a 25' taper to the roadway as shown in Figure 9-01 below.

Maintain 15' of vertical clearance (including trees and vegetation) along roadways and driveways.

Remove/modify combustible vegetation and flammable materials 10 feet from both sides of roadways and driveways.



## Turnout with a Hydrant

When a hydrant is placed at the turnout the total width of the road with turnout will be a minimum of twenty six feet (26') in width through the turnaround.